



BANGALORE WATER SUPPLY & SEWERAGE BOARD

WATER QUALITY REPORT

Date of Sampling	09-Jun-2026	Division	North - 1
Analysis Date	09-Jun-2026	Sub Division	North-1-2
Analysis Completed On	11-Jun-2026	Service Station	Ganganagar
RR Number	N-325626	Reference Sample Id	
Address	No.73/1, Siddhartha Public School, 1st Cross, Chowdaiah Block, R.T.Nagar.		

Sl.No.	Parameters	Unit	Result	As per IS-10500:2012		Remarks
				Desirable Limit	Permissible Limit	
1	pH	-	7.90	6.5 - 8.5		
2	TDS	mg/L	246.0	500	2000	
3	Turbidity	NTU	2.33	1	5	
4	Hardness	mg/L	160.0	200	600	
5	Calcium	mg/L	32.8	75	200	
6	Alkalinity	mg/L	152.0	200	600	
7	Chloride	mg/L	30.40	250	1000	
8	Magnesium	mg/L	18.95	30	100	
9	Flouride	mg/L	0.45	1	1.5	
10	Iron	mg/L	BDL	1		
11	Aluminium	mg/L	BDL	0.03	0.2	
12	Sulphate	mg/L	17.22	200	400	
13	Nitrate	mg/L	0.34	45		
14	Residual Chlorine	ppm	0.2	0.2	1	
15	Total Coliform	or Present/Absent for 1	Absent	Shall not be detectable		
16	E.coli	or Present/Absent for 1	Absent	Shall not be detectable		
17	Manganese	mg/L	BDL	0.1	0.3	
18	Color	Hazen	<5	5	15	
19	Conductivity	uS/cm	390			

Result SPP

End of Result

Notes: # - Results applicable only for above samples and tested parameters
SPP: Satisfactory for Potable Purpose, NSPP: Not Satisfactory for Potable Purpose:

This is an auto generated report from the WQMS Software

Alphouse Pruthi
PRINCIPAL
SIDDHARTHA PUBLIC SCHOOL
No. 1, Chowdaiah Block, R. T. Nagar.
Bangalore-560 032

Pruthi
CHAIRMAN
SIDDHARTHA PUBLIC SCHOOL
No.1, Chowdaiah Block, R.T. Nagar
Bangalore - 560 032