



BANGALORE WATER SUPPLY & SEWERAGE BOARD

WATER QUALITY REPORT

Date of Sampling	03-Jul-2021		Division	North East	
Analysis Date	03-Jul-2021		Sub Division	North East - 3	
Analysis Completed On	05-Jul-2021		Service Station	Ganganagar	
RR Number	325626		Sample Id	GNR202140081	
Address	No.73, 1st Cross, Chowdaiah Block.				
Reference Sample Id	NA		Reference Sample Date	NA	
Sl.No.	Parameters	Unit	Result	As per IS-10500:2012	
				Desirable Limit	Permissible Limit
1	pH	-	7.90	6.5 - 8.5	
2	Turbidity	NTU	2.07	1	5
3	Residual Chlorine	ppm	0.2	0.2	1
4	Total Coliform	MPN or CFU /100ml	Absent	Shall not be detectable	
5	E.coli	MPN or CFU /100ml	Absent	Shall not be detectable	
6	TDS	mg/L	160.3	500	2000
7	Hardness	mg/L	NA	200	600
8	Calcium	mg/L	NA	75	200
9	Magnesium	mg/L	NA	30	100
10	Aluminium	mg/L	NA	0.03	0.2
11	Manganese	mg/L	NA	0.1	0.3
12	Alkalinity	mg/L	NA	200	600
13	Colour	Hazer.	NA	5	15
14	TOC	mg/L	NA	-	-
15	Flouride	mg/L	NA	1.0	1.5
16	Nitrate	mg/L	NA	45	
17	Sulphate	mg/L	NA	200	400
18	Lead	mg/L	NA	0.01	

Result

SPP

End of Result

Notes: # - Results applicable only for above samples and tested parameters

Remarks: ## SPP: Satisfactory for Potable Purpose, NSPP: Not Satisfactory for Potable Purpose

For SIDHARTHA PUBLIC SCHOOL

Secretary

This is an auto generated report from the WQMS Software

SIDHARTHA PUBLIC SCHOOL
1, Chowdaiah Block, R.T. Nagar
BANGALORE - 560 032